

2340500 SUPERPAVE ASPHALT BASE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

D4 Construction

Comments: (1-3-12)

The proposed deletion of text is for the purpose eliminating redundancy. I didn't see any reference to permissible variations in transverse or longitudinal grade in 334-5. So perhaps you should consider leaving the reference to 200-7 in the spec.

Response: Agree with the reviewer. The reference to 200-7 will remain. Thank you for the comment.

Change made.
