

5340000 CONCRETE SOUND BARRIERS.
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Mario Paredes
352-955-6690

Comments: (10-14-11)

Copolymer already means 2 or more monomers. No need to include multipolymer.

Response:

The sentence is corrected to read as follows:

Shims must be either stainless steel (Type 304 or 316) or engineered copolymer plastic.

Pat McCann

pat.mccann@dot.state.fl.us

Comments: (11-9-11): District 4 Construction has the following comments: "534-54 Shop Drawing Submittal. Submit only the information requested,"; Not sure what we mean by "the information requested" Where is the information requested located in our documents? "The template shall be such that the installation tolerances can be held." Please change "held" to "maintained".

Response:

The word "below" is added the first sentence as follows:

Do not include shop drawings of the basic concrete panel details, submit only the information requested below.

The word "held" is changed to "maintained" as follows:

The template shall be such that the installation tolerances can be maintained.
