

1450302 GEOSYNTHETIC REINFORCEMENT  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Neil Monkman  
[neil.monkman@wrightg.com](mailto:neil.monkman@wrightg.com)

Comments: (6-26-12)

As long as revisions are being considered for the 2nd paragraph I believe it should be made clear in this paragraph to state "...three randomly selected REPRESENTATIVE samples..." Currently the specification seems to allow the sampler to obtain a sample that may not be representative of the entire stockpile. Understanding that FM test methods may give specific verbiage that defines this, putting that single word in the specification (which is what everyone references in the field) eliminates the need to bring another document into the situation to verify compliance.

**Response:**

\*\*\*\*\*