

9310100 Metal Accessory Materials for Concrete Pavement and Concrete Structures  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Pat McCann  
(954) 777-4387

Comments: (3-26-12) D4 Const. has the following comment: 931-1.1 Last paragraph, first sentence; Suggest you delete "and certified mill analysis" since this sentence is referring to sampling. We already have the cert.'s at this point.

Response: There are two requirements, each having a different frequency. The certified mill analysis frequency is described in the first paragraph. The physical sample that is tested by the State Materials Office is described in the second paragraph. The physical sample includes the certified mill analysis matching the bar that is physically sampled. The second paragraph is revised to reflect this as the requirement for clarification.

\*\*\*\*\*