

1250902 EXCAVATION FOR STRUCTURES AND PIPE.
COMMENTS FROM INTERNAL/INDUSTRY REVIEW



Paul Harkins
863-519-2226
paul.harkins@dot.state.fl.us

Comment: (5-21-13) What density is required when you have cover less than 15"?

Response: 100% of the Standard Proctor maximum density as determined by AASHTO T99, Method C, or the requirements of 125-8.3.3.1 when applicable per the first sentence of the paragraph in 125-9.2.1. No Change Made.
