

4001501 CONCRETE STRUCTURES  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Daniel Sheer  
414-4130  
[daniel.sheer@dot.state.fl.us](mailto:daniel.sheer@dot.state.fl.us)

Comments: (6-3-13, Internal)

Minor suggested modification (~~delete highlighted text~~) at the bottom of the Section:

~~The following materials: 4 parts of ordinary gray portland cement, 1/2 part of white portland cement, 1 part of fly ash and 2 to 4 parts of sand. The blended mortar must closely match the color of the filled element once fully cured and the proportion of white portland cement may be adjusted to achieve as close a match as possible. Regardless of the type patching mortar used, provide a final mortar surface that has smoothness and texture closely resembling the existing surface.~~

Response: Discussed with Daniel Sheer and will change the text to agree with his intent regarding the comment. See revised text above highlighted in yellow

Change made.

\*\*\*\*\*