

4250000 INLETS, MANHOLES, AND JUNCTION BOXES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Paul Harkins
863-519-2226
paul.harkins@dot.state.fl.us

Comments: (5-21-13)

Correct me if I am wrong, but we do not allow or want to allow rectangular structures out of brick. For clarification, is the intent to allow use of brick on rectangular structures limited to when adjusting structures and then only to a height not to exceed 12"? Would it be better to show under adjusting structures?

Response:
