

5220000 Concrete Sidewalk and Driveways
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Previte, John

Comment: (6-3-13) Do we want to include the term “turnouts” to match standard indexes? The common definition of driveway connotes a private passageway, whereas a turnout is the apron portion of the drive constructed on FDOT right-of-way.

drive-way
/'draɪv,weɪ/ Show Spelled [draɪv-vey] Show IPA
noun
1.
a road, especially a private one, leading from a street or other thoroughfare to a building, house, garage, etc.
2.
any road for driving on.

World English Dictionary
driveway ('draɪv,weɪ) ⓘ
— n
a private road for vehicles, often connecting a house or garage with a public road; drive

Response:
(By Dan Sheer, State Specs. Engineer) Yes indeed – ‘turnout’ is a good modification if that truly is the proper term and will make us consistent with the Standard Index. In your definition, it states that it is a ‘private’ road connecting to a ‘public’ road – isn’t that in fact a potential condition as well where we are making an access point for a private road to intersect/access a public one? I can see where we’d potentially have two public roads intersecting and therefore we have the ‘turnout’ situation, but we also have private accesses that intersect the public road as well.

John Mauthner, P.E.

Comment: (5-28-13) 522-1, 522-3, Why do we repeat Specification verbiage. already included in 520?

Response:

Scott Williams
swilliams@ajaxpaving.com

Comment: (7-1-13) I would like to see concrete removal to stay its own item and not part of clearing & grubbing. For two reasons one harder to track second if we are not replacing the s/w curb or driveways we should get paid a higher fee than adding it to clearing & grubbing .

Response:

John Mauthner

John.Mauthner@dot.state.fl.us

Comment: (7-1-13) Subarticle 522-9, Method of Measurement - should read, "Sidewalk curb ramps," instead of "Ramps," as shown in the proposed revision in red. This comment is based on Subarticle 522-1, Description - which states "Sidewalk will include sidewalk curb ramps."

Response:
