

5600705 COATING NEW STRUCTURAL STEEL
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Rudy Powell
414-4280

Comments: (6-3-13, Internal)

Recommend not basing the reduced frequency of testing on the Contractor's work shift. What if the Contractor works a 10 or 12 hour shift? What if the Contractor stops work early- 6 hour shift?

Response: Reference to "shift" will be changed to "day".
Change made.
