

6350202 PULL, SPLICE, AND JUNCTION BOXES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
D4 Const

Comment: (6-11-13)

In regards the allowance of power and communications in the same pull box: I suggest against this change in the interest of safety. I would also think there would be resistance to this change from maintaining agencies as well. Aside from possible safety concerns, isn't there a concern that a power surge or defect in power cable splice or ground could damage communications cable?

Response:

Vinod Tuli, P.E.
Vinod.tuli@dot.state.fl.us

Comment: (6-14-13) Currently we run the signal cables and loops cables in separate runs and pull boxes on signal projects. In sub-article 635-3.1, it seems that you are taking out the text which explicitly says not to run them in same pull box. Is this the intent or the next sentence in the text covers this and existing text was superfluous?

Response:
