

4001101 CONCRETE STRUCTURES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Richard DeLorenzo
352-955-6667
richard.delorenzo@dot.state.fl.us

Comment: (2-24-14, Internal)
Suggest the following highlighted changes:

→ **400-11.1 Separation of Surfaces:** In general, separate all contact surfaces between superstructure and substructure or end walls and between adjacent superstructure sections by a layer of ~~559b#~~ **Type II (No. 30)** roofing felt ~~meeting the requirements of ASTM D-226.~~

Response:
