

4001604 CONCRETE STRUCTURES  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

-----  
D3 Materials Office

Comment: (6-20-14)

It should also prohibit the use of brackish and salty water.

Response:

\*\*\*\*\*

D4 Construction

Comment: (6-30-14)

Since we're removing "potable" there is no standard for water. Although the beginning of 400 references 923, one could argue that this is only referring to the concrete mix and not other uses of water. Suggest referencing 923 in this section as well or note that any reference to "water" in 400 shall meet 923.

Response:

\*\*\*\*\*

Shailesh Patel  
407-482-7829  
[shailesh.patel@dot.state.fl.us](mailto:shailesh.patel@dot.state.fl.us)

Comment: (7-1-14)

1. Does this mean the Contractor can use seawater to cure the concrete?

Response:

2. Recommend where they have removed potable (water)...replace with fresh (water).

Response:

\*\*\*\*\*