

1050808 CONTRACTOR QUALITY CONTROL GENERAL REQUIREMENTS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Paul Vinik  
352-955-6686  
[paul.vinik@dot.state.fl.us](mailto:paul.vinik@dot.state.fl.us)

Comments: (5-27-15, Internal)

Comments for section 105:

**105-8.8.7.3 Flexible Filler Injection:** Perform all filler injection operations under the direct supervision of a Filler Injection Foreman who has **ASBI** certification in the injection process being used, or verifiable experience performing injection of similar flexible filler on at least two projects. Provide at least two CTQP Qualified Grouting Technicians, one of whom must be a Level II CTQP Qualified Grouting Technician, both of whom must be present at the site of the flexible filler injection work during the entire duration of the operation.

Provide a Filler Injection Quality Control (QC) Inspector who has **ASBI** certification ( I did not see where this acronym was defined?) in the injection process being used, or verifiable experience performing injection of similar flexible filler on at least two projects.

Response:

\*\*\*\*\*