

4300201 PIPE CULVERTS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Larry Ritchie
FDOT
(850) 414-4168

Comments: (6-8-15)

I believe the Round Rubber Gaskets referenced in 430-2.1 are the gaskets used for pipe joints (Section 942-1) as opposed to the resilient connectors referenced in this Spec. change.

Response:

The change to only apply when resilient connectors are used as identified in section 430-4.1. The wording has been modified to eliminate confusion.

FDOT, D5
Construction

Comments: (6-22-15)

Why use the word resilient? The Contractor's and Department's interpretation of resilient maybe be different.

Response:

The change to only apply when resilient connectors are used as identified in section 430-4.1. The wording has been modified to eliminate confusion.
