

4430100 FRENCH DRAINS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

D3 Construction  
850-330-1206

Comments: (8-18-15, Late comment)

443-2.1 - for types of pipe listed (5) and (7) consider combining them. Define them as All Corrugated Polyethylene Pipe.

Response: 443-2.1(5) specifies Corrugated High Density *Polyethylene* (HDPE) pipe while (7) specifies Corrugated *Polypropylene* pipe. HDPE is different from polypropylene and cannot be combined as “Corrugated Polyethylene Pipe.”

I'll insert HDPE in brackets to highlight the difference a little better.

Change made.

\*\*\*\*\*