

5560200 JACK AND BORE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Neil Monkman
239-462-7371
neil.monkman@wrightg.com

Comments: (6-5-15)

If the casing is extended structure to structure how is the contractor going to mud (seal) around the pipe that goes in the structure from the back side. Does the index account for this space? Might just be something I am not seeing.

Response:

Gordon Wheeler
FDOT
850-414-4366
gordon.wheeler@dot.state.fl.us

Comments: (6-8-15)

The proposed change should specify that it is being used as a carrier for drainage. There are other products that the pipe may be used as a carrier for, such as gas, potable water, sewage, etc

Response:

Chad O. Rucks (via Deborah Ihsan)
(772) 429-4938

Comments: (7-1-15)

556-2 Materials: Suggest reworking final sentence to read "When the Plans show that the carrier pipe is to be encased, extend the casing the entire length from drainage structure to drainage structure.

Response:
