

# EXPECTED IMPLEMENTATION JANUARY 2016

## **639 ELECTRICAL POWER SERVICE ASSEMBLIES.** **(REV 7-14-15) (FA 7-14-15) (1-16)**

SUBARTICLE 639-3.3 is deleted and the following substituted:

**639-3.3 Electrical Service Wire:** Use No. 6 AWG stranded copper wire with XHHW (cross-linked polyethylene (XLPE) high heat-resistant, water-resistant) insulation, rated at 600 V in dry and wet condition for connections between service disconnect and traffic cabinet, unless otherwise shown in the Plans.

SUBARTICLE 639-5.1 is deleted and the following substituted:

**639-5.1 General:** Measurement for payment will be in accordance with the following work tasks.

Payment for electrical service wire between service disconnect and traffic cabinet is based upon the distance of the cable run and includes payment for all conductors used in the run. For lighting applications, payment for service conductors will be made in accordance with Section 715.

Payment for conduit and electrical service wire which is vertically attached to the electrical power assembly is considered incidental and paid under item 639-1.

D

R

A

F

T