

1210200 FLOWABLE FILL
INTERNAL/INDUSTRY REVIEW COMMENTS

Chad Rucks
772-742-4938
chad.rucks@dot.state.fl.us

Comments: (12-17-15)

The Ground Tire Rubber does not have a strong bond between cement and fine aggregates. Therefore consider the following comment- Note 3 for the spec may be modified as :- 3. GTR may replace up to 20% of the fine aggregate. The use of GTR may be limited to cellular and excavatable flowable fill.

Response:
