

3300502 HOT MIX ASPHALT – GENERAL CONSTRUCTION REQUIREMENTS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

D5 Construction  
386-943-5347

Comments: (11-24-15)

Mix distribution devices should be required anytime 24” or greater extendable screeds are being used. So you could just take out what is struck out in screen.

Response: Please note that changing the word, “provided” to “submitted”, does not (nor is it intended to) change the Specification requirement. Rather the wording change is part of an effort to make language consistent throughout the Specifications.

To be clear, the Specification allows the requirement to be waived if the manufacturer provides the required documentation stating the devices are not needed.

No change made.

\*\*\*\*\*