

4100200 PRECAST CONCRETE BOX CULVERT  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Dee Kane

dee.kane@edeliveryservicesllc.com

Comments: (12-9-15)

410-4.1.1: First sentence has "including reinforcing steel grade" Shouldn't the word "steel" be removed? 410-14: The last sentence has "reinforcing steel (roadway)". Shouldn't the word "steel" be removed?

**Response:**

The word "steel" is in 410-4.1.1 because steel rebar is still permitted in precast box culverts, and is more likely to be used than FRP rebar. The word "steel" must remain in 410-14 as it is part of the pay item name.

\*\*\*\*\*