

4551505 STRUCTURES FOUNDATIONS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Brian Hermany  
561-370-1140

Comments: (12-23-15)

"In some cases the Engineer may require the Contractor to overream the outside diameter of the casing before placing the casing." Statement does not make sense to me. The casing is not being over reamed the excavation is.

Response: The outside diameter of the casing would be the diameter after overreaming the excavation. Sentence changed to "In some cases the Engineer may require the Contractor to overream to the outside diameter of the casing before placing the casing.  
Change made.

\*\*\*\*\*