

9230300 WATER FOR CONCRETE
INTERNAL/INDUSTRY REVIEW COMMENTS

Chad Rucks
772-429-4938
chad.rucks@dot.state.fl.us

Comments: (12-17-15)

For SM 2320 B the standard methods reference Alkalinity, but not acidity. Recommend removing “Acid” from the chemical test name in the table and just have “Alkalinity”.

Response:
