

9310101-2 METAL ACCESSORY MATERIALS FOR CONCRETE  
PAVEMENT AND CONCRETE STRUCTURES  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Brian Hermany (via Deborah Ihsan)  
561-370-1140

Comments: (12-3-15)

It appears that we may be allowing “TEST” Bundles/pieces of rebar to be shipped to the job. I know that is not the intent. Suggest rewording the last sentence to “Samples shall be obtained from steel that is delivered to the jobsite” This will allow the random sample to be taken from anywhere on the project or if suspect material is encountered.

Response:

\*\*\*\*\*