

6200302 GROUNDING AND LIGHTNING PROTECTION
INTERNAL/INDUSTRY REVIEW COMMENTS

Elizabeth Birriel
921-7361
elizabeth.birriel@dot.state.fl.us

Comments: (8-2-16)

1. 620-3.2.2 Minimum Resistance Not Required: No resistance measurements for most of these elements doesn't make any sense to me. I believe resistance measurements should be required, especially for all traffic signal intersection elements where 120 VAC is present! (Comment from Carl Morse).

Response:

Katie King
386-943-5333
katie.king@dot.state.fl.us

Comments: (9-26-16)

Add a condition to the site resistance measurements in the 3rd paragraph that restricts testing during rain events. Consider adding additional points to testing because repeat-ability of the test measurements to verify after certification has been an issue.

Response:
