

6460200 ALUMINUM POLES, PEDESTALS, AND POSTS
INTERNAL/INDUSTRY REVIEW COMMENTS

Daniel Strickland
414-4352
daniel.strickland@dot.state.fl.us

Comments: (10-20-16. Internal)

Recommend rewording the highlighted portion below to say “in accordance with” instead

→ → → 3. Fastening: Provides for fastening to a foundation with four 3/4" inch anchor bolts located 90 degrees apart, ~~and a~~The bolt circle diameter ~~shall of 14 inches must be based on the base manufacturer recommendations~~. The base design must allow for bolts that are placed off-center.¶

Response:
