

4250202 INLETS, MANHOLES, AND JUNCTION BOXES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Stefanie Maxwell
414-4140
stefanie.maxwell@dot.state.fl.us

Comments: (3-2-17, Internal)

What would trigger the Engineer to request the documentation on the sand?

Response: This comment has been addressed by making it mandatory for the Engineer to request documentation.

D5 Construction Office

Comments: (4-20-17)

In regards to the 425-2.2 Mortar spec, comment would be to include “.....confirming the sand or sand substitute meet the requirements” into the update.

Response: This comment has been addressed by adding the suggested phrasing.
Change made.
