

4310600 PIPE LINER
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Bob Burleson
FTBA

Comments: (6-7-17)
Comment I received:

I think they should keep it separate. Often times they could get away with just cleaning or just grouting without lining. There is too much risk associated with assumptions of number of joints to grout and will increase the departments cost to line. While we are on the subject. I believe the department should look into using their pre-qualification class codes for maintenance and construction to get rid of the knuckleheads. How do we go about doing that?. We are bidding against home builders now on desilting jobs.

Response: If all that is needed is desilting, Section 430 would apply. For the purposes of this Specification, the liner and all other associated work should be lumped together. In order to determine whether or not a liner is needed, desilting and video inspection will be required ahead of time. So, if any desilting is needed at the time the liner is installed it should be minor and will part of the cost of the liner. If there is a question of how many joints or how much flowable fill is needed that information would also be available from the previous inspection of the pipe. This Section does not cover pre-qualification.
No change made.
