

5600705 COATING NEW STRUCTURAL STEEL
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Tim McCullough

352-955-6681

timothy.mccullough@dot.state.fl.us

Comments: (4-10-17, Internal)

Please include the following highlighted revision:

→ → **560-2.4 Soluble Salts Test Kit:** Use a soluble salts test kit in accordance with SSPC-Guide⁹¹⁵ utilizing a **Class A Table 1** retrieval method. Ensure the test sleeve or cell creates a sealed, encapsulated environment during ion extraction and is suitable for testing all structural steel surfaces. As an alternative, electronic conductivity meters approved for use by the Engineer may be used.¶

Response:
