

6300305 CONDUIT
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Henry Smith
(813) 740-2300
Henry.Smith@kci.com

Comments: (Industry, 10-9-17)

Dan,

I tried to comment on the website, however the drop-down menu did not include the attached specification number?

I have a question about conduit connections of dissimilar materials. It is my understanding that when HDPE pipe is connected to PVC pipe a mechanical splice device (such as an e-lock, see attached) is necessary. This is because PVC adhesive does not work on HDPE and HDPE adhesive does not work on PVC.

However, I do not see where the conduit specifications where this is required?

Response:
