

9230100 WATER FOR CONCRETE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
Brian Price
881-4245
brian.price@dot.state.fl.us

Comments: (10-4-17)

So base on this memo the producer will be able to use recycled and reclaimed water for batching of 346 or 347 concrete. Is this correct.

Response: This change was to clarify the use of waters identified in Section 923 for batching both structural and non-structural concrete

No change made.
