

EXPECTED IMPLEMENTATION JULY 2018

620 GROUNDING AND LIGHTNING PROTECTION (REV 9-28-17) (FA 11-8-17) (7-18)

SUBARTICLE 620-2.4 is deleted and the following is substituted:

620-2.4 Grounding Conductors: For installing grounding conductor in conduit, provide an insulated conductor that is stranded in accordance with ASTM B8 and color code the grounding conductor green. For installing grounding conductor without conduit, provide bare solid copper wire meeting the requirements of ASTM B3 for grounding conductors. Connect the grounding conductor from the system ground bus or barrier plates to the ground rod assembly. Size equipment grounding conductors according to NEC Section 250.122. Size grounding electrode conductors according to NEC Section 250.66.

D

R

A

F

T