

9920102 HIGHWAY LIGHTING MATERIALS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Arthur Berger
(850) 414-5368
Arthur.berger@dot.state.fl.us

Comments: (Internal, 9-7-18)

ALL JOBS

HIGHWAY LIGHTING MATERIALS
(REV 8-28-18)

The entire luminaire shall be one color, and that color shall be a standard grey for all luminaires.

SUBARTICLE 992-1.2 is deleted and the following substituted:

992-1.2 Luminaires, Driver, etc.: All luminaires shall be one of the products listed in the Department's Approved Product List (APL). Manufacturers seeking evaluation of their product shall submit an application in accordance with Section 6.

The light source for luminaires shall be either light emitting diodes (LED), magnetic induction or plazma induction.

The luminaire housing shall be constructed of precision cast aluminum with a corrosive resistant polyester powder coat finish. ~~The standard color shall be gray.~~ The housing shall have an electrical terminal block to attach the luminaire cable and a hinged door ^{which that} provides direct access to internal parts. Hinged doors are not required for high mast luminaires and underdeck luminaires. All hardware on the exterior of the housing shall be stainless steel. The refractor and lens shall consist of glass or an optical grade polymer. The manufacturer shall place a permanent tag in the luminaire housing imprinted with: the manufacturer name, luminaire voltage, lamp wattage, and provide a blank area for the Contractor to inscribe the installation date.

Luminaires shall meet the following requirements: UL 1598 listed and labeled for installation in wet locations by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL), be capable of maintaining 94.1% intensity at 10,000 hours with an ambient temperature of 25°C (IES LM-80) and have IESNA light distribution curves (IES LM-79) by an EPA recognized laboratory.

The driver shall be rated for 100,000 hours and have a power factor greater than or equal to 90% at full load with a total harmonic distortion less than or equal to 20% at full load. The fixture shall accommodate a circuit voltage of 480V.

Luminaires shall be provided with a minimum 10kV/10kA internal surge suppression module meeting UL 1449/ANSI C62.41.2 Category C.

The manufacturer shall submit a five-year non-prorated full warranty on all components of the luminaire to the Department. The warranty shall begin on the project acceptance date and include all components of luminaire.

Response:

Karen Byram
(850) 414-4353
Karen.byram@dot.state.fl.us

Comments: (Internal – 9-13-18)

Question, is the need for an access being removed or is the necessity of a hinge on the access being removed? The way it reads, I would assume access is still required but a hinged door is optional.

Response:

