

Specification Section 938

Subarticle 938-4

ORIGINATION

Date: 5-21-2025

Name: Ronald Simmons

Email: Ronald.Simmons@dot.state.fl.us

COMMENTARY

To align with the testing method, the unit of sulfate limitation and the sampling time need to be updated.

INDUSTRY COMMENTS AND RESPONSES

(Please note all comments and responses are verbatim as received. The Specifications Office does not alter typos or grammar.)

BLACK = Comment **BLUE** = Specifications Response **GREEN** = Change Made to Specification

Name: Oliver Chung

Date: 7-24-25

COMMENT: Total Sulfate Ions should be 3 mg/g, not 30 mg/g. Please verify.

RESPONSE: Agreed. 3 mg/g is correct.

ACTION TAKEN:

Revision made.