

# Specification Section 120

## Subarticle 120-6

### ORIGINATION

Date: 6-20-2025

Name: Jason Russell

Email: Jason.Russell@dot.state.fl.us

### COMMENTARY

Changes necessary to eliminate pay item/quantity issues on resurfacing projects where soil is required to meet shoulder drop requirements. Splitting the sod and soil pay item into individual pay items for clarity.

### INTERNAL COMMENTS AND RESPONSES

*(Please note all comments and responses are verbatim as received. The Specifications Office does not alter typos or grammar.)*

BLACK = Comment **BLUE** = Specifications Response **GREEN** = Change Made to Specification

Name: Kandarappallil Jose

Date: 7-28-25

COMMENT: 1200603 - section 120-9.2.4 - Compaction of Grassed Areas: It is suggested to modify the proposed change to read as by striking off section 570 – “Construct shoulder areas on existing facilities using shoulder drop-off soil in accordance with Section 570 and Standard Plans 570-010” Reason: The standard plan 570-010 advise the use of select material per general note 2 B on the shoulder material. Quoting spec 570 is not needed.

**RESPONSE: The reference to Section 570 in specification Section 120 is required. Section 570 includes the details for the drop-off soil and the pay item.**

**Please note, the Standard Plan Index 570-010 referenced in your comment is the current Standard Plan. The changes to Section 120 and 570 are accompanied by changes to Standard Plan Index 570-010.**

### **ACTION TAKEN:**

**None.**