

Specification Section 975

Subarticle 975-6

ORIGINATION

Date: 5-21-26

Name: Mateo Carvajal

Email: mateo.carvajal@dot.state.fl.us

COMMENTARY

The existing language needs to be revised to explicitly allow water-repellent coatings as a Class 5 option. These coatings have shown acceptable performance on Department projects through Technical Special Provisions. Adding this option to the specification will provide clearer guidance and more flexibility for District use.

INTERNAL COMMENTS AND RESPONSES

(Please note all comments and responses are verbatim as received. The Specifications Office does not alter typos or grammar.)

BLACK = Comment **BLUE** = Specifications Response **GREEN** = Change Made to Specification

Name: Karen Byram

Date: 6-3-26

COMMENT: Section 975-1.3 APL has must modified. With the 975-1.3 change, most of these comments can be deleted. only the Table changes and 975-6.3 Water-Repellent Coatings: Water-Repellent coatings shall be of water-based silicone acrylic, need to remain. 975-1.3 also need to be changed because of changes to 562. 975-4 must now be listed on the APL for BABA compliance.

RESPONSE:

The modifications proposed by the APL Office were incorporated.

ACTION TAKEN:

A new table was added to address the APL documentation.

APL

N/A