

# Maintenance Specification Section

## SPM5270000

### ORIGINATION

Date: 12-16-2024

Name: Deanna Hutchison

Email: Deanna.Hutchison@dot.state.fl.us

### COMMENTARY

Changes needed to provide clarity on work included when replacing detectable warnings and remove non-applicable plan quantity language.

### INTERNAL COMMENTS AND RESPONSES

*(Please note all comments and responses are verbatim as received. The Specifications Office does not alter typos or grammar.)*

BLACK = Comment **BLUE** = Specifications Response **GREEN** = Change Made to Specification

Name: Jason Smith

Date: 1-6-2025

COMMENT: Under 527-3 Construction Requirements Should we put, if necessary, in the wording as this leaves it up to interpretation for the installer and inspector. If we want them to remove all material it could say something like Prepare the surface, including complete removal of existing detectable warning material up to and including adhesives, bolts, tiles, or composites remaining from previous installations.

**RESPONSE: The intent is for the removal of all material remaining from previous installation(s) if it is present, as there will be some locations where there is no material to be removed.**

**ACTION TAKEN: Changed “if necessary” to “if present” to clarify the intent.**